



- Notes
- 1) Drawings are not to scale. All dimensions are in feet and inches.
  - 2) Unless otherwise indicated, connections 3" and smaller are MPT. Connections 4" and larger are grooved to suit a mechanical coupling and beveled for welding.
  - 3) Dimensions showing location of coil and basin connections are approximate and should not be used for prefabrication of connecting piping.
  - 4) For weight loadings and support requirements, refer to the suggested steel support drawing.
  - 5) Heaviest section is the combined weight of fan and coil sections, refer to the PC2/PF2 Counterflow Induced Draft Coil Products rigging and assembly manual for suggested lifting method.
  - 6) The area above the discharge must be unobstructed.
  - 7) Do not support piping from unit connections. All necessary piping supports to be supplied by others.
  - 8) M = Motor location

Model Number	Shipping Weight	Operating Weight	Heaviest Section
DC2-2436-2506-240	132219	168400	28102

ORDER NO: Q14029031210

DATE: 1/24/2014



Unit Print  
Quad Cell 24'x36'

DRAWING NUMBER:  
UP-Q14029031210