



NOTES:

1. (M) - FAN MOTOR LOCATION
2. THE SPRAY PUMP SHOULD BE SIZED FOR 545 GPM AND 3 PSIG AT THE INLET CONNECTION.
3. 3/4" DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING.
4. HEAVIEST SECTION IS UPPER SECTION.
5. * APPROXIMATE DIMENSIONS. DO NOT USE FOR PRE-FABRICATION OF CONNECTING PIPING.
6. MPT DENOTES MALE PIPE THREAD.
FPT DENOTES FEMALE PIPE THREAD.
BFW DENOTES BEVELED FOR WEDLING.

WEIGHTS			NO. SHIPPING SECTIONS
SHIPPING	OPER.	HEAVIEST SECTION	
14620	17760	12660	2

MODEL NUMBER: (1) ATC345 CONDENSER

CERTIFIED FOR: THE AUSTIN COMPANY PROJECT: RUSSELL STOVER CANDIES
 CUSTOMER ORDER NO. 505-35 EVAPCO NO. 975161M
 CAPACITY 3609 MBH R-717 REFRIG. 96.3 ° COND ° SUCT 78 ° W.B.
 FAN MOTOR HP (1) 20 (2 SPEED/1 WINDING) ELEC. SPEC. 460/60/3
 PUMP MOTOR HP N/A ELEC. SPEC. N/A

REMARKS: UNIT ARRANGED FOR REMOTE SUMP OPERATION. UNIT FURNISHED WITH (1) LADDER, (1) VIBRATION CUTOUT SWITCH AND STAINLESS STEEL SUMP SCREEN. DRIVE SIZED FOR 0" ESP.



EVAPORATIVE CONDENSER

REV. 2/5/98 JMR

CA081212ERC-03